



John Benson, City Manager
400 N. Washington St.
Beeville, TX 78102
361-358-4641

Mandatory Language for a Maximum Contaminant Level Violation MCL, LRAA/ TTHM

The Texas Commission on Environmental Quality (TCEQ) has notified the **CITY OF BEEVILLE PWS 0130001** public water system that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for total trihalomethanes. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for total trihalomethanes to be 0.080 milligrams per liter (mg/L) based on a locational running annual average (LRAA) and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for total trihalomethanes indicates a compliance value in;

- 3Q2023 of .086 mg/L for 4000 Louise Dr, Beeville (DBP2-01)
- 3Q2023 of .087 mg/L for 112 E Roberts, Beeville (DBP2-04)

Trihalomethanes are a group of volatile organic compounds that are formed when chlorine, added to the water during the treatment process for disinfection, reacts with naturally-occurring organic matter in the water.

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidney, or central nervous systems, and may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

We are taking the following actions to address this issue (TTHM / HAA5):

The City of Beeville and Inframark, our water treatment plant operator, is in communications with the Texas Commission on Environmental Quality (TCEQ) to change the coagulant in our treatment process to help address the current issue. Inframark is also flushing more frequently to help with the age of water in our water distribution system.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact:

Water System Official: John Benson
Area code + phone number: 361-358-4641 ext. 202
Posted /Delivered on: January 8, 2024